

POPE ENGINEERING

CIVIL ENGINEERING ~ LAND SURVEYING

SAMUEL G. POPE P.E. 65228, P.L.S. 8903

1540 Harrah Drive, Willits, CA 95490

Tel 707-459-3893 Cell 707-321-7458

pope1911@gmail.com

Mendocino County

MAY 04 2023

Planning & Building Services

October 21, 2022

Anna Sommers
114 Shawnee Trail
Aurora, OH 44202


Civil Engineering Services
5600 Westview Road, Willits APN 147-061-13-01

Dear Anna,

On October 18, 2022 a water availability test was conducted at the above referenced parcel per the requirements stipulated in Mendocino County form 26-05.

Two springs on the property were tested, the first at approximate GPS Coordinates 39°21'25" N, 123°24'36" W was measured at 6 Minutes per Gallon. The second spring at the lower portion of the property was located at approximate GPS Coordinates 39°21'13" N, 123°24'30" W was measured at 5 Minutes 20 seconds per Gallon, for a combined rate of **0.18 Gallons Per Minute**. There is at least one other spring on the property but as I was not able to measure it at the source it was not tested. While on-site I observed several full tanks of water consisting of 36,500 gallons of storage. The water testing was conducted by holding a 1-quart container under the stream of a pipe which was directly connected to the spring box and timed with a digital stopwatch.

Sincerely,



Samuel G. Pope, P.E., P.L.S.